



# A WESCO SEPTIC SERVICE, INC.

Snohomish, Wa

## OPERATIONAL REPORT

Customer: Jack Greathouse  
 Address: 2604 260th Ave Se Snohomish Wa 98075  
 Service Date: 7-7-7

Approximate size of Septic Tank: 750  
 Septic Tank Pumped: Yes  No

Single compartment:  Double compartment

Condition of Septic Tank: Pass  Fail

Condition of Inlet Baffle: Pass  Fail

Condition of Center Baffle: Pass  Fail

Condition of Outlet Baffle: Pass  Fail

Type of Outlet Baffle: Filtered:  Non filtered

Depth of floating Mat in: First compartment: 0  
 Second compartment: N/A

Depth of Sludge in: First compartment: 4FF  
 Second compartment: 6"

Effluent running back into tank from drainfield: Yes  No

Does this system appear to include a pump: Yes  No

Comments: Has a single compartment septic tank!  
Also has a 350 gallon gray water tank  
just off that.

INSPECTION BY: [Signature]